



## CERTIFICATE OF ANALYSIS

<b>Tested for:</b> Konia Australia Pty Ltd T/As Konia Water 3/26 Argyle St Albion, 4010 Qld Australia  <b>Attention:</b> Valentine Nzvimbo (Business Development Manager)	<b>Certificated No:</b>  10-033 B  <b>Revision No:</b>  1	 NATA Accredited Laboratory Number:  15435  NATA endorsed test report. This document shall not be reproduced, except in full.   Ian Miller Microbiologist 9-Feb-2010
	<b>Invoice Number:</b>  994	

<b>Date samples received:</b> 28-Jan-10	<b>Testing Commenced:</b> 28-Jan-10
---	-------------------------------------

<b>Receipt Temperature:</b> Chilled	<b>Storage Temperature:</b> Refrigerated
-------------------------------------	--

<b>Product Description:</b> Konia Water from Air with Pi Filter
---

Analysis#	Results	L.O.R	Units	Method Code	Limits <sup>^</sup> HEALTH	Limits <sup>^</sup> ASTHETIC
Total Cyanide *	<0.004	0.004		EFF037	0.08	
Bicarbonate	67	1	mg/L	EFF031		
Arsenic (Total)	<0.001	0.001	mg/L	EWM01	0.007	
Boron (Total)	<0.2	0.2	mg/L CaCO <sub>3</sub>	EWI01	4	
Cadmium (Total)	<0.001	0.001	mg/L	EWM01	0.002	
Chromium (Total)	<0.005	0.005	mg/L	EWI01	0.05	
Copper (Total)	<0.01	0.01	mg/L	EWI01	2	1
Iron (Total)	<0.01	0.01	mg/L	EWI02	500	250
Potassium (Total)	0.60	0.2	mg/L	EWI02	0.003	
Calcium (Total)	11.9	0.1	mg/L	EWI02	0.0007	
Magnesium (Total)	0.12	0.01	mg/L	EWI02		
Manganese (Total)	<0.001	0.001	mg/L	EWI01	0.5	0.1
Sodium (Total)	<1	1	mg/L	EWI01		180
Nickel (Total)	<0.01	0.01	mg/L	EWI01	0.02	
Lead (Total)	<0.001	0.001	mg/L	EWM01	0.01	
Selenium (Total)	<0.001	0.001	mg/L	EWM01	0.01	

Zinc (Total)	<0.02	0.02	mg/L	EW102		3
--------------	-------	------	------	-------	--	---

Ammonia *	<0.2	0.2	mg/L	EFF003		0.5
Chloride *	2.6	0.3	mg/L	EFF011		250
Flouride	0.15	0.05	mg/L	EFF015	1.5	
Hardness (Total)#	30	1	mg/L CaCO <sub>3</sub>	EFF025		200
Nitrite *	<0.03	0.03	mg/L	EFF005	3	
Nitrate	0.68	0.4	mg/L	EFF004	50	
Sulphate *	<10	10	mg/L	EFF016	500	250
pH	7.09 @ 22°C			EFF006		6.5 - 8.5
Total Dissolved Solids	84.5	2	mg/L	EWI01	0.1	

**DEFINITIONS**

^ Australian Drinking Water Guidelines 2004

> = Greater than

< = Less than

\* = Not Covered by scope of accreditation

Results were reported on an "as received" basis unless otherwise indicated. Sampling was carried out by the customer and results reported pertain only to the samples submitted, responsibility for representative sampling rests with the customer.